



Momentum Technologies, Inc.  
 1507 Boettler Road  
 Uniontown, Ohio 44685  
 ☎ 330/896-5900 Fax 330/896-9943  
 www.momentumtech.net

Date: February 27, 2004  
 MTi Project No.: EX27B4A  
 Fax No.: 216-281-0034

## TECHNICAL SERVICES REPORT

**TRUCO Inc.**

**ATTN.: Christopher Hoskins**

3033 W. 44<sup>th</sup> Street, Cleveland, OH 44113

Ref. No.: \_\_\_\_\_ Project ID: **EX27B4A** Date: **February 27, 2004**

**ABSTRACT:** Peel Strength Analysis per ASTM D903 of acrylic and solvent based coatings on several substrates.

**SAMPLE DESCRIPTION:** Samples were prepared by TRUCO. No reinforcement was embedded into the coatings as normally prescribed by ASTM D903/C794.

<b>TEST RESULTS:</b>	<u>Sample Description</u>	<u>Result</u>
	Acrylic on EPDM	0.411 lbf/in.
	Solvent Based on EPDM	3.946 lbf/in.

If you have any questions or require any additional information, please call us at 330/896-5900.

Sincerely,

Brian T. Doran,  
*Laboratory Chemist*

The information presented in this publication is based upon the research of Momentum Technologies, inc. (MTi) and is to the best of its knowledge accurate. However, no guarantee of its accuracy can be made since MTi has no control over the conditions under which its products may be used by others. MTi assumes no liability for its use, or the failure of products described herein. MTi MAKES NO WARRANTIES EXPRESSED OR IMPLIED, OF MERCHANTABILITY, FITNESS, PATENT INFRINGEMENT, OR OTHERWISE. MTi SHALL NOT BE LIABLE FOR SPECIAL, INCIDENTAL AND/OR CONSEQUENTIAL DAMAGES. No statement contained herein shall be construed as a recommendation or inducement to infringe existing patents or as an endorsement of products of specific manufacturers. ALL TEST REPORTS SHALL NOT BE REPRODUCED, EXCEPT IN FULL WITHOUT THE WRITTEN APPROVAL OF MOMENTUM TECHNOLOGIES, INC.

*Accreditations*



ISO/IEC 17025



*Associations*



Roof Coating  
 Manufacturers  
 Association